

# CHECKLIST Regional WQCV Control Measure Standard

## REGIONAL WQCV CONTROL MEASURE STANDARD Criteria

Control Measure(s) must be designed to accept the drainage from the applicable development site. Stormwater from the site must not discharge to a water of the state before being discharged to the Regional WQCV Control Measure. The Regional WQCV Control Measure must be designed to provide treatment and/or infiltration of the WQCV for 100% of the applicable development site.

*Complete checklist if using the Regional WQCV Control Measure Standard to meet Design Standard requirements.*

Project Name:		
Preparer	COG	Requirements
		Control Measure(s) are designed to accept the drainage from the site
		Stormwater from the site must not discharge to a water of the state before being discharged to the Regional WQCV Control Measure
		The Regional WQCV Control Measure is designed to provide treatment and/or infiltration of the WQCV for 100% of the site
		BMP ID/location:
		See Drainage Report section:

*If less than 100% of the site is treated, complete the following:*

Preparer	COG	Requirements	
		% of site not treated by control measures (not to exceed 20% or 1 acre):	
		%	size (acres)
		Provide explanation that the excluded area is impractical to treat:	
		Provide explanation that another BMP is not practicable for the untreated area:	